

Have all the fire hydrants been tested and what were the results?

The fire hydrants are tested yearly and were tested within the last 6 months. All but one are functional. The fire hydrant at 1st and Elkhart is on the repair/replace list.

Regarding the meeting with RockPro : It was stated that would have a significant impact on revenue which may affect the timing of the rate increase. At which meeting was this discussed?

There was no meeting with RockPro. This was mentioned on a Manager's Report, was not an agenda item, no further action was taken.

An agenda item is one that must be discussed, proposed or legal action taken, including any deliberations by a quorum with respect to that action. Anyone may suggest an agenda item, but that does not mean will appear on the agenda for action to be taken.

The number of people served fluctuates from 300(2021) to 397(2022) to 350(2023) to 229(2024). What could explain that large (168) of a discrepancy?
The number of "people served" includes the number of individuals in town at the time the service was provided, including RV parks. We currently have 178 connections. Each RV park has one connection that may serve more than one person per space. Individual residences often serve more than one individual.

The 2024 report says 29,280 was purchased and 29,280 was delivered. Considering the high percentage loss each month, how is that possible?

This means that we bought and paid for 29,280 units delivered to our tank at Mineral Park. We pay for it even it is subsequently considered non-revenue water.